

# Declaration of Conformity

According to ATEX Directive 2014/34/EU

Actuators type A1, A2, A3, A4 and A5, double acting and spring return, with option -E have been designed and manufactured according to ATEX Directive 2014/34/EU and are marked:

 II 2 G Ex h IIC T6-T3 Gb  
 II 2 D Ex h IIC T65-T125 °C Db

Above stated product have been subjected to a conformity assessment procedure according to Internal Quality Assurance Procedures.

**Valid harmonised standards have been:**

EN IEC 60079-0:2018 EN ISO 80079-36:2016 EN ISO 80079-37:2016

**Other technical specifications:**

EN 1127-1:2019

Säffle 2024-09-13

Somas Instrument AB



Johan Bergsland  
Quality Assurance Manager  


---

<b>Postal address</b> Somas Instrument AB P.O. Box 107 SE-661 23 SÄFFLE Sweden	<b>Telephone</b> +46 533 69 17 00	<b>Internet</b> www.somas.se  E-mail sales@somas.se	<b>Bank account</b> 99602603604253 Nordea Bank AB Abp, filial i Sverige SWIFT-adress NDEASESS IBAN SE4495000099602603604253	VAT No. SE556219766401 REG No. 556219-7664
--	--------------------------------------	---	---	---

Visit and delivery address: Norrlandsvägen 26-28, SE-661 40 SÄFFLE, SWEDEN