



SCORE (EUROPE) LIMITED

Engineering Research, Design, Manufacture & Repair

Fire Test Certificate

In Accordance with Specifications B.S. 6755 PART 2 1987

a BUTTERFLY VALVE VSS/3 size 80mm (3")

serial no. 2835/90 seat material SS2377 SST.

manufactured by A.B. SOMAS

has been tested by Score (Europe) Limited on 12th JUNE 1990

at Score's COWDENBEATH Works and has complied in full with the requirements.

Test carried out by J.R. SMITH and R. HEPBURN Score (Europe) Limited

Test witnessed by M. AXELSSON Manufacturer

To Certifying Authority

SCORE (EUROPE) LIMITED	
QUALITY ASSURANCE INSPECTION	
SIGNATURE	<i>[Signature]</i>
DATE	19/6/90



Project: Somas AB
Order No. 05062

Certificate No.: EDB 000118/3

Client: Score (Europe) Limited

Office: EDINBURGH

Client's Order No.: 2826/8123

Date: 15th June, 1990

Inspection dates
First: 12.6.90

Order Status: Incomplete

Final: 14.6.90

This is to certify that at the request of Score (Europe) Limited, the undersigned Surveyor attended their Works at Woodend, Cowdenbeath, Fife for the purpose of witnessing a Fire Test on a Butterfly Valve, stated to be manufactured by Somas AB, Sweden. Details of the Valve are as follows:-

Size: 80 mm Bore
Class: PN25 ANSI 150
Material of Construction: Body: Cast Stainless Steel
Shaft: AISI 329 Hard Chromed
Disc: AISI 316
Graphite Seals
Drawing No. D-566
Valve Stamped: 2835/90.8123/1A
Gearbox Nameplate Details noted as: G/B GBE Mastergear
C8200 MZ 30/039

Temperature calorimeter cubes were placed as follows:-

1. Stem Flame Temperature
2. Bottom Flame Temperature
3. Stem Calorimeter Block
4. Bottom Calorimeter Block
5. Box Temperature/Trunnion Calorimeter Block
6. Skin Temperature

The Fire Test was carried out in accordance with B.S. 6755 Part 2 1987.

The Valve was mounted into a test stand with calorimeter cubes and flame environment thermocouples in their appropriate location, which were connected to a Chessell Model 4001 temperature recorder with automatic printout facilities, Serial Number 0586-410469, calibration of which was verified. A calibrated test pressure gauge 0 - 60 Bar, Serial No. S11876680 was also used.

Both/

Continued

Surveyor to Lloyd's Register

Control Number EDB 000118/3

Both the inlet and outlet pipework was connected to the Valve with the Valve in the partially open position the system was filled with water and the air purged out.

The system was checked for leaks by pressurising to 14.5 bar and found tight.

During the burn period the pressure was maintained at 14.5 bar by occasional manual adjustment.

On completion of the burn period of 30 minutes duration the Valve was cooled naturally to 100°C.

The results of the Fire Test were then recorded as follows:-

Through seat leakage at high test pressure of 14.5 bar during burn period = Zero over 30 minutes.

External leakage (high test pressure) during burn and cool down periods = Zero

Through seat leakage at low test pressure of 2.0 bar after cool down = Zero over 5 minutes.

External leakage (low pressure test) after cool down = Zero

Torque to operate Valve at high test pressure differential = 20 newton metres.

External leakage with valve pressurised to 14.5 bar in fully open position = zero over 5 minutes.

The test was concluded at this point.

The valve was dis-assembled and examined to verify compliance with Drawing Number D-566 and found to comply.

In respect of the test results now stated it is considered that the test valve complies with the requirements of B.S. 6755 Part 2 1987.


.....
Surveyor to Lloyd's Register

T.A. DALLING

10



SCORE

Engineering Research, Design, Manufacture & Repair

Page 20 of 22

DETAILS OF RANGE QUALIFIED

VALVE TESTED TO B.S. 6755 PART 2 1987

RANGE QUALIFIED IS:- SIZE: 3", 4", 5", 6" (DN80, 100, 125, 150)

CLASS: 150, 300 (PN16, 25, 40)

SCORE (EUROPE) LIMITED	
QUALITY ASSURANCE INSPECTION	
SIGNATURE	<i>[Handwritten Signature]</i>
DATE	19/6/90