

Declaration of Conformity

According to ATEX Directive 2014/34/EU

Actuators type A1, A2, A3, A4 and A5, double acting and spring return, with option -E have been designed and manufactured according to ATEX Directive 2014/34/EU and are marked:

Ⓔ II 2 G Ex h IIC T6-T3 Gb

Ⓔ II 2 D Ex h IIC T65-T125 °C Db

Above stated product have been subjected to a conformity assessment procedure according to Internal Quality Assurance Procedures.

Valid harmonised standards have been:

EN IEC 60079-0:2018 EN ISO 80079-36:2016 EN ISO 80079-37:2016

Other technical specifications:

EN 1127-1:2019

Säffle 2024-09-13

Somas Instrument AB



Johan Bergsland
Quality Assurance Manager


Postal address
Somas Instrument AB
P.O. Box 107
SE-661 23 SÄFFLE
Sweden

Telephone
+46 533 69 17 00

Internet
www.somas.se

E-mail
sales@somas.se

Bank account
99602603604253
Nordea Bank AB Abp, filial i Sverige
SWIFT-address NDEASESS
IBAN SE4495000099602603604253

VAT No. SE556219766401
REG No. 556219-7664

Visit and delivery address: Norrlandsvägen 26-28, SE-661 40 SÄFFLE, SWEDEN